

### Test Report

Quality Standard		Parameters as desired				
Issued to	-	Open Sky School, Sector 5, Part 6, Gurgaon				
Kind attn.	-	Mr.				
Analysis no.	-	25122708				
Nature of Sample	-	Water Sample marked Drinking				
Sample received on	-	27 <sup>th</sup> December 2025				
Report Date	-	31 <sup>st</sup> December 2025				
Analysis Dates	-	27 <sup>th</sup> December 2025 to 31 <sup>st</sup> December 2025				
Sample receipt	-	Picked by Lab				
Sample Packing	-	Sterilized and Pet Bottles				
	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS as per IS:10500	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS 1622	10	No Relaxation
	E.Coli	CFU/100ml	Absent	IS 1622	Absent	Absent
Physical	pH	Unit Less	7.51	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	110	IS 3025 Part 14	—	—
	Turbidity	NTU	1.0	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	67	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO <sub>3</sub>	mg/l	36	IS 3025 Part 23	200	600
	Total Hardness as CaCO <sub>3</sub>	mg/l	43	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	13.2	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	—
Remarks: The no. of parameters tested is 14 only. The report is issued subject to the terms & conditions as mentioned overleaf.						
Chemist	Authorized Signatory					

Reviewed by Sign :	
Designation : Quality Analyst	



  
 Principal  
**Open SKY**  
 Gurugram